



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	4077-2265:0500
CATEGORY:	4077 - FIRE PROTECTIVE CURTAIN
LISTEE:	U.S. Smoke & Fire 12310 Pinecrest Rd, Suite 300, Reston, VA, 20191 Contact: Sadeghian, Steve (888) 917-8777 Email: Asagp85@gmail.com
DESIGN:	Model Hose Stream 120®Fire Curtain and Frame System. The curtain is constructed of two layers of fine fabric-like stainless steel mesh coated with an organic material. The fire curtain consists mainly of a spindle in a header box which holds the rolled-up curtain, side guides which provide a track for it to raise and lower and a bottom bar which seals the fire curtain against the floor. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	90 min. per UL10B with hose stream
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model designation and SFM label.
APPROVAL:	Listed as a fire-protective curtain for nonstructural applications. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instructions Manual for details.
NOTES:	

01-02-18 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/27/2022

Listing Expires: 06/30/2023

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division